



Model A320V3 Dehumidifier

Part #71000082 Power Cord Installation Instructions



CAUTION

If the supply cord is damaged, it must be replaced by the manufacturer, its service agent or similarly qualified persons in order to avoid a hazard.

United States Installation: Make all electrical connections in accordance with the current edition of the NEC ANSI/NFPA 70 and any local codes or ordinances that may apply.

Canada Installation: Make all electrical connections in accordance with the current edition of the Canadian Electrical Code CSA C22.1 and any local codes or ordinances that may apply.

	Model A320V3
Voltage	277 VAC, single phase, 60Hz
Recommended Breaker Size	20 A
Power Cord Part Number	71000082
Power Cord Type and Length	SJT, I7-20P, 10 feet
Receptacle	SJT, L7-20R

1. Remove the electrical service panel from the dehumidifier.
2. Route the power cord wires through the opening in the dehumidifier and secure with provide strain relief
3. Insert the black service wire into the L1 terminal and the white service wire into the L2 terminal.
4. Insert the ground wire (bare or green) of the electrical service into the ground lug and secure it in place by tightening the ground lug screw.
5. Reattach the electrical service panel to the dehumidifier.

